



Product Service

CERTIFICATE

No. B 120494 0004 Rev. 00

Holder of Certificate: **Korner SRL**
Via Alessandro Volta N. 12
20047 Cusago MI
ITALY

Certification Mark:



Product: **Connection device
(Terminal block with cable gland)**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 64100180755502A

Valid until: 2027-01-16

Date, 2023-03-31

(Martin Ma)



Product Service

CERTIFICATE

No. B 120494 0004 Rev. 00

Model(s): OK-B02, OK-T02, OK-T03, OK-P20,
OK-P25, OK-P20T

Parameters:

Rated insulation voltage:	450V
Rated connecting capacity:	0.5mm ² (OK-B02) 1.5mm ² (other models)
Rated connecting range:	0.2 - 0.5mm ² (OK-B02) 0.5 - 1.5mm ² (other models)
IP degree:	IP68 (IPX8: 4m, 120h)
Type of terminal:	Screwless-type, with direct pressure
Number of terminals:	Multiway 2 (OK-B02, OK-T02);
Number of poles:	3 (OK-T03, OK-P20, OK-P20T); 5 (OK-P25)
Kind of connector:	Flexible
Maximum ambient temperature:	105°C
Material of the cable glands:	Non-metallic
Sealing system of cable glands:	With a single orifice seal

Tested according to: EN 60998-2-2:2004
EN 60998-1:2004
EN 62444:2013